


Permit No. PO-B-215
County COOS
Permit Fee \$200.00

AMENDED FOR
S02 SIP REVISION



STATE OF NEW HAMPSHIRE
Air Resources Agency

Permit to Operate

This Certifies that
James River Corporation - Groveton Group

has been granted a Permit to Operate for
C.E. Boiler #5

~~device which emits air pollutants into the ambient air as set forth in
equipment registration forms (ARCA 1-6) filed with this Agency under
date of May 25, 1985~~

~~in accordance with RSA 105-G of the New Hampshire laws of 1984 (amended 1987)~~

~~This permit is valid until July 31 1986~~

~~Request for permit renewal is subject to Agency requirements and must
be accompanied by the appropriate equipment registration forms.~~

~~This permit is valid provided the device is operated in accordance with all the
legally enforceable conditions specified in Items 1 through 5 below:~~

~~1. The emission of air pollutants are limited by NH Air Resources Commis-
sion Regulations (308-2810)
CHAPTERS AIR 400 and 1200; BART AIR 1302~~

2. The maximum operating rate is limited to:

720
10 lb/hr, gal/hr, tons/hr, million BTU/hr gross input
of #6 fuel oil at 2.2% sulfur, maximum WARRANT

3. The operating hours of the device are limited to:

24 hrs/day 300 days/yr

4. The opacity of emissions may not exceed 40 %.

5. Other conditions

A. The Boiler Plant (Boilers #1, #2, #4, and #5) and the Recovery
System Kiln are limited to emissions equivalent to those from
burning 25,000 total gallons per day of fuel oil with 2.2% sulfur
content. A daily log of total equivalent oil usage shall be main-
tained and available at the Groveton facility for inspection by
the NHARA.

SEE ATTACHED SHEET FOR ADDITIONAL PERMIT CONDITIONS.

~~The owner or operator of the device covered by this permit must notify the Agency within 10 calendar days of any change in
operating conditions of the device covered by the permit which represent a significant deviation from the permit conditions.
Any unreasonable modification shall be reported to the Agency which would result in emissions greater than those permitted in this
permit must be reported to the Agency within 10 calendar days of the change in operating conditions.~~

~~This permit (if necessary) should be appropriately displayed near the device for which it is issued.~~

Concord, NH September 6, 19 85

Dennis R. Lundeville
Director, Air Resources Agency

James River Corporation
Groveton Group

ATTACHMENT

PO-B-215
C.E. Boiler #5

Condition A continued

Oil usage for Boiler #5 is to be calculated as follows:

Oil Usage = (Actual Gallons Burned) X
(Ratio of Actual Sulfur Content of
Fuel Burned to 2.2)

Where: Actual Gallons Burned are derived from steam
production data and Actual Sulfur Content is
derived from the maximum sulfur content of the
three most recent fuel supplier certificates.

Dated: September 6, 1985